



NOV 28 2005

Jeb Bush
Governor

M. Rony François, M.D., M.S.P.H., Ph.D.
Secretary

November 21, 2005

Mr. Phillip Morgan, National Sales Manager
Advanced Aeration, Inc.
102 Midway Industrial Park
Angleton, Texas 77515


Dear Mr. Morgan:

I am responding to your November 14, 2005 request for a "Letter of No Objection" to the use of Vacuum Bubble[®] Technology in onsite systems in Florida. In reviewing your request we have found that Aerob-A-Jet, Model 100, received a letter of no objection from this office on February 10, 1993 (attached). Based on the documentation submitted with your February 25, 2005, request for approval that your Vacuum Bubble[®] Technology Aerator Model 100 is identical the department has no objection to the use of your product subject the terms below:

1. The system must be installed in the first chamber of a multi-chambered tank or an outlet filter must be installed. No structural modifications to the existing tank or lid are allowed.
2. Installation of your unit shall be considered an alternative repair subject to s. 64E-6.015(3), FAC. Please note that alternative repair methods cannot be used where the absorption surface of the drainfield is within 6 inches of the wet season water table.
3. Installation and use shall be as detailed in the Installation and Operating Manual submitted with your February 25, 2005 request. Any changes to the manual must be reviewed and approved by the department prior to distribution. The unit must be installed through the manholes in the treatment unit either by drilling or replacing the existing manhole cover.

Be advised that the department is not a testing agency. This determination reflects only a review of the information submitted by you for compliance with Florida law and rules. The product evaluation does not investigate the validity of performance claims by manufacturers. Departmental acceptance must not be interpreted as certifying effectiveness, endorsing or recommending use of your product. The department does not assume liability for any promise, guarantee or expectation from purchasing or using your product. The department reserves the right to withdraw acceptance if the product is modified after product evaluation by the department, if the product creates a sanitary nuisance, or otherwise operate in a manner detrimental to the public's health. If we may be of further assistance or should you have any additional questions regarding this letter, please call Paul Booher at (352) 955-2159.

Sincerely,


Gerald R. Briggs, Chief
Bureau of Onsite Sewage Programs

Enclosure(s)



11-28-05 scanned LB

Division of Environmental Health, Bureau of Onsite Sewage Programs
4052 Bald Cypress Way, Bin #A08, Tallahassee, Florida 32399-1713